

**University of Illinois Department of  
Agricultural Engineering  
BEES Lab**

---

**Project Number:** 01172

**Test Date:** August 20, 2001

**Fan**

*Make:* American Coolair

*Model #:* FGBC52K

*Manufacturer:* American Coolair

*Blade Size:* 52.8

*Orifice Dia.:* 53.1"

**Blade**

*Number:* 3

*Shape:* propeller

*Material:* cast aluminum

*Pitch:* -

*Clearance:* 0.1"

**Shutter w/ bell mouth inlet**

*Material:* plastic

*# of Doors:* 16

*# of Columns:* 3

*Door Length:* 17.1"

*Location:* intake

**Other Attachments:**

Discharge cone 29" deep, 53.1" i.d., 62.5" o.d.  
Belt tensioner

**Motor**

*Make:* AO Smith

*Model #:* 92GC868

*H.P.:* 3/4

*Amps:* 6.8/3.4

*Volts:* 115/208-230

*RPM:* 1725

*S.F.:* 1.3

**Drive**

*Drive Pulley Dia.* 2.3"  
AK23

*Axle Pulley Dia.:* 9.5"

**Housing**

*Material:* fiberglass

*Intake Area:* 56" x 56"

*Discharge Area:* 53.1" dia.

*Depth:* 24" top  
21.5" bottom

**Guards**

*Description:* wire

*Spacing:* 2" concentric

*Location:* exhaust

# TEST RESULTS

## AMERICAN COOLAIR FGBC52K

	Static Pressure	Speed	Airflow	Efficiency
	<u>in. water</u>	<u>rpm</u>	<u>cfm</u>	<u>cfm/Watt</u>
Test: 01172	0.00	409	23,100	33.4
Fan description:	0.05	408	20,600	28.6
52" belt drive, 3/4 hp AO Smith 92GC868	0.10	407	17,300	23.5
motor, fiberglass housing, plastic shutter,	0.15	409	10,700	15.5
Guard and discharge cone	0.20	410	2,800	4.2

---