

University of Illinois Department of
Agricultural Engineering
BEES Lab

Project Number: 03050bd

Test Date: April 29, 2003

Fan

Make: Big Dutchman

Model #: 60-36-5204

Manufacturer: Canarm

Blade Size: 35.9"

Orifice Dia.: 36.8"

Blade

Number: 4

Shape: propeller

Material: galvanized steel

Pitch: -

Clearance: 36.8"

Shutter

Material: plastic

of Doors: 12 per column

of Columns: 2

Door Length: 20"

Location: intake

Other Attachments:

Motor

Make: Marathon

Model #: AWA56T17T5600A

H.P.: 1/2

Amps: 2.0-1.8/0.9 60Hz
1.8-2.0/9-1.0 50 Hz

Volts: 208-230/460 60 Hz
190-240/380-480 50 Hz

RPM: 1725/1425

S.F.: 1.00

Drive

Drive Pulley Dia. 3.3" o.d.

Axle Pulley Dia.: 10.0" o.d.

Housing

Material: fiberglass

Intake Area: 42" x 41"

Discharge Area: 40.3" dia.

Depth: 36" top
26" bottom

Guards

Description: wire

Spacing: 2"

Location: exhaust

TEST RESULTS

BIG DUTCHMAN 60-36-5204

Test: 03050bd

▲ 3 phase

Fan description:

36" belt drive, ½ hp Marathon AWA56T17T5600A
motor, fiberglass housing, plastic shutter and guard

Static Pressure
in. water

Speed
rpm

Airflow
cfm

Efficiency
cfm/Watt

0.00

545

10,810

22.9

0.05

544

9,740

19.6

0.10

543

8,590

16.5

0.15

542

6,720

12.5

0.20

542

4,020

7.4

0.25

539

2,840

4.8

0.30

537

1,940

3.0