

Bioenvironmental and Structural Systems Lab
Fan Description FormProject Number: 96312 Series/Test: / Test Date: November 19, 1996 File Name: **Fan**Make: Chore-TimeModel #: 38434-4822Serial #: -Manufacturer: Chore-TimeBlade Size: 48"Orifice Dia.: 48.5"**Blade**Number: 3Shape: propellerMaterial: galvanized steelPitch: -Clearance: 0.3"Hub Diameter: -**Shutter**Material: plastucNumber Doors: 15 per rowNumber Rows: 2Door Length: 26.2"Location: intake**Other Attachments****Motor**Make: GEModel #: 5KCR49SN0293TSerial #: WJJ15006H.P.: 1Amps: 9.6/5.2-4.8Volts: 115/208-230RPM: 1725S.F.: 1.0Drive Pulley Dia.: 2.8" o.d.
AK28Axle Pulley Dia.: 8.5" o.d.Center Spacing: -**Housing**Material: galv. steelIntake Area: Discharge Area: 52.4"x52.4"Depth: 28"**Guards**Description: welded wireSpacing: 1" x 2"Location: exhaust

TEST RESULTS

CHORE-TIME 38434-4822

	Static Pressure	Speed	Airflow	Efficiency
	<u>in. water</u>	<u>rpm</u>	<u>cfm</u>	<u>cfm/Watt</u>
Test: 96312	0.00	552	19500	19.5
Fan description:	0.05	551	18400	17.8
48" belt drive, 1 hp GE 5KCR49SN0293T	0.10	550	17200	16.2
motor, steel box housing, plastic shutter	0.15	550	15900	14.6
and guard	0.20	547	14100	12.7
	0.25	548	11700	10.4
	0.30	533	8000	7.0
