

Bioenvironmental and Structural Systems Lab
Fan Description FormProject Number: 96320 Series/Test: / Test Date: November 19, 1996 File Name: **Fan**Make: Chore-TimeModel #: 38437-4822Serial #: -Manufacturer: Chore-TimeBlade Size: 48"Orifice Dia.: 48.5"**Blade**Number: 3Shape: propellerMaterial: galvanized steelPitch: -Clearance: 0.3"Hub Diameter: -**Shutter**Material: plasticNumber Doors: 15 per rowNumber Rows: 2Door Length: 26.2"Location: intake**Other Attachments****Motor**Make: GEModel #: 5KCR49SN0293TSerial #: WJJ15006H.P.: 1Amps: 9.6/5.2-4.8Volts: 115/208-230RPM: 1725S.F.: 1.0Drive Pulley Dia.: 2.8" o.d.
AK28Axle Pulley Dia.: 8.5" o.d.Center Spacing: -**Housing**Material: galv. steelIntake Area: Discharge Area: 52.3"x52.3"Depth: 21"**Guards**Description: wireSpacing: 1" x 2"Location: exhaust

TEST RESULTS

CHORE-TIME 38437-4822

	Static Pressure	Speed	Airflow	Efficiency
	<u>in. water</u>	<u>rpm</u>	<u>cfm</u>	<u>cfm/Watt</u>
Test: 96320	0.00	551	19500	19.8
Fan description:	0.05	550	18500	18.3
48" belt drive, 1 hp GE 5KCR49SN0293	0.10	549	17300	16.7
motor, steel box housing, plastic shutter	0.15	548	15900	14.8
and guard	0.20	547	14200	13.1
	0.25	546	11800	10.8
	0.30	546	8700	7.7
